



## ADDENDUM NO. 2

Date: October 17, 2023

Bid Due Date: October 24, 2023  
at 3:00 P.M. (Local Time)

Bid Name: Eastside/GTEC Infrastructure

Bid No.:GCRA-240010-DH

NOTE: This Addendum has been issued only to the holders of record of the specifications.

The original Specifications remain in full force and effect except as revised by the following changes which shall take precedence over anything to the contrary:

1. Any questions shall be submitted in writing to the City of Gainesville Purchasing Division by 3:00 p.m. (local time), October 16, 2023. Questions may be submitted as follows:

**email: [holders@gainesvillefl.gov](mailto:holders@gainesvillefl.gov)**

2. Please find attached; take possession of these documents and incorporate them into your bid price and schedule:
  - a) Copy of the cone of silence information (Financial Procedures Manual Section 41-524 Prohibition of Lobbying in Procurement Matters.
  - b) FDOT Driveway Permit
  - c) FDOT Drainage Connection Permit
  - d) Geotech Report No 15579A from GSE dated November 2022.

The following are answers/clarifications to questions received:

3. Question: What provisions are allotted for contractor parking on site?  
Answer: **Lot 1 and 2 are NOT owned by the city and thus no parking is allowed. Contractors may park ONLY on-site on Lot 3 or Lot 4 as depicted on the construction plans.**
4. Question: What are the working hours allowed for MOT and road work? Is night work allowed on Hawthorne Road?  
Answer: **The FDOT permit has no specific restrictions on work, however further MOT approval is required by FDOT, refer to FDOT permit page 42 of 42. Also refer to C0.10 MOT notes and City of Gainesville notes regarding preparation and approval of a MOT plan.**
5. Question: Who is the UJB developer?  
Answer: **The city is the project developer and UF Health owns land (lot 1 and 2) within the development.**

6. Question: Regarding the wetlands area, will delineation and remediation be needed?  
Answer: **The wetlands shown have been delineated and approved for removal by SJRWMD and Alachua County. All impacts have been mitigated as required by the appropriate agencies.**
7. Question: Do we need to provide pre and post surveying?  
Answer: **Refer to C0.10 City of Gainesville Notes regarding survey requirements.**
8. Question: Do we need to handle the detour on 8<sup>th</sup> Ave once work has begun, or will the city be handling that?  
Answer: **Contractor is responsible for all MOT. Refer to C0.10 MOT Notes and City of Gainesville Notes regarding preparation and approval of an MOT plan.**
9. Question: Are there any soil borings? Will some be provided?  
Answer: **Yes, Soil profiles are on the plans, a complete report is included with this addendum and is provided for informational purposes only; do not assume such data is a guarantee of the depth, extent, or character of material present and the report will not be incorporated into the final construction documents.**
10. Question: Since there is not a detail for the milling and paving areas, would you like to stick with the 3", same as the asphalt profile in the standard detail or could the subcontractor do the mill and pave as something more typical like 1.5"?  
Answer: **Mill a minimum of 1.5" and replace with a minimum of 1.5" of SP 12.5 for all areas requiring milling.**

ACKNOWLEDGMENT: Each Proposer shall acknowledge receipt of this Addendum No. 2 by his or her signature below, **and a copy of this Addendum to be returned with proposal.**

CERTIFICATION BY PROPOSER

The undersigned acknowledges receipt of this Addendum No. 2 and the Proposal submitted is in accordance with information, instructions, and stipulations set forth herein.

PROPOSER: \_\_\_\_\_

BY: \_\_\_\_\_

DATE: \_\_\_\_\_

# CITY OF \_\_\_\_\_ FINANCIAL SERVICES GAINESVILLE PROCEDURES MANUAL

## 41-524 Prohibition of Lobbying in Procurement Matters

Except as expressly set forth in Resolution 170116, Section 9, during the Cone of Silence as defined herein no person may lobby, on behalf of a competing party in a particular procurement process, City Officials or employees, except the Procurement Division or the procurement designated staff contact person. Violation of this provision shall result in disqualification of the party on whose behalf the lobbying occurred.

Cone of Silence period means the period between the issue date which allows for immediate submittals to the City of Gainesville Procurement Division in response to an invitation to bid, or a request for proposal, or qualifications, or information, or an invitation to negotiate, as applicable, and the time that City Officials or the Procurement Division, or City Department awards the contract.

Lobbying means when a person seeks to influence or attempt to influence City Officials or employees with respect to a decision of the City, except as authorized by procurement procedures.